

Sika Bel LLC  
ag. Mikhanovich  
223070 MINSK REGION  
WEISSRUSSLAND

Date: 14.09.2021

## Inspection certificate EN 10204 3.1

Article Name : SPL G-15 light grey  
Product Number : 162844  
Inspection lot No : 1110908-09

Production Date : 08.09.2021

Characteristic	Method	Limits	Results
Determination of visible defects	EN1850_2	-	OK
Thickness (final test)	EN1849_2	1,43 ... 1,65 mm	1,45
Tensile strength longitudinal	E12311_2	min. 1000 N/50mm	1260
Elongation at break longitudinal	E12311_2	min. 15,0 %	18,0

This certificate is computer generated and therefore unsigned

Sika Manufacturing AG  
Quality Management  
Behadin Kodraliu  
+41 58 436 62 22  
Murtenstrasse 13  
CH-3186 Düringen

BUILDING TRUST

